

LED PENDANT DOWNLIGHT
INSTALLATION GUIDE

Eurolumen

MODEL ELX509

PENDANT / CEILING CANOPY / CABLE GRIP

1



CHECK PRODUCT AND MOUNTING COMPONENTS

2



SWITCH OFF AND ISOLATE MAINS POWER

3



FIX CANOPY CROSSBAR TO CEILING

4



CONNECT TERMINAL / SUPPORT PENDANT

5



SECURE CANOPY / LOCK STRAIN RELIEF

6



CHECK SUSPENSION / POWER ON

WIRING DIAGRAM

POWER SUPPLY
220V AC

CEILING TERMINAL
L / N / PE

CANOPY / DRIVER
CONFIRM LABEL

LED LUMINAIRE
TEST OUTPUT

1. Isolate the mains supply before opening or installing the luminaire.

2. Connect L, N and protective earth only as marked on the supplied terminal.

3. Keep conductors and the terminal block fully enclosed by the body or canopy.

4. Confirm the selected control interface matches the ordered configuration.

FOLLOW THE PRODUCT LABEL AND LOCAL ELECTRICAL INSTALLATION RULES.

INSTALLATION DATA

MODEL	ELX509
INSTALLATION	PENDANT DOWNLIGHT
MOUNTING	CANOPY / CROSSBAR / CABLE GRIP
PRODUCT SIZE	DIA. 105 mm
INPUT	220V AC
POWER OPTIONS	15 / 20 / 25 / 28 W
CCT / CRI	2700-4000K / CRI 90
BEAM OPTIONS	15 / 24 / 36 / 55 DEG.
CONTROL	DALI / BLUETOOTH / 0-10V / ON-OFF
LOCATION	INDOOR / DRY LOCATION / IP20



Installation of this product must be performed under the guidance of qualified technical personnel.

Switch off and isolate the mains supply before installation, adjustment or maintenance.

If the product has been updated, contact Eurolumen to confirm the latest installation instructions.

Eurolumen reserves the right of final interpretation. Retain this guide with the project records.



WARNING

- INSTALL ONLY WITH MAINS POWER OFF AND BY QUALIFIED PERSONNEL.

- VERIFY CEILING FIXINGS, TERMINALS AND MECHANICAL SUPPORTS BEFORE POWER ON.

CE

RoHS

IP20

INDOOR