

LED IN-GROUND LIGHT INSTALLATION GUIDE

Eurolumen

MODEL ELA719

MODEL-SPECIFIC BURIAL SLEEVE SYSTEM

1

EXACT SOURCE GEOMETRY

D250 x H188.5 mm

SUPPLIED PRODUCT IMAGE

D228 mm

VERIFY ELA719 / D250 FACE / MATCHING BURIAL SLEEVE

2

D228 mm RECESS/DATUM

CHECK SUBSTRATE / DRAINAGE / CABLE ROUTE BEFORE CUTTING

MARK D228 SLEEVE POSITION / PROVIDE DRAINAGE

3

MATCHING D228 mm BURIAL SLEEVE

SET VERTICAL / TOP EDGE FLUSH / PROVIDE FREE DRAINAGE

SET D228 x H219 mm SLEEVE FLUSH AND LEVEL

4

ELA719 FACTORY LEAD / SUPPLY PER PRODUCT LABEL

IP-RATED CONNECTION

VERIFY CABLE SEAL

JOIN IP-RATED CONNECTOR / LOCK / SEAL

5

LOWER THE COMPLETE FIXTURE INTO ITS MATCHING SLEEVE

SECURE FACE AS SUPPLIED / KEEP TOP FLUSH AND LEVEL

LOWER THE COMPLETE FIXTURE / SECURE FACE / CONFIRM FLUSH SEAT

6

FINAL COMMISSIONING ONLY

POWER CONTROL UNIFORM OUTPUT

CHECK FLUSH SEAT / WATER SEAL / DRAINAGE / AIM WHERE APPLICABLE

POWER ON / COMMISSION / CHECK OUTPUT, SEAL AND DRAINAGE

ELA719 POWER / CONTROL CONNECTION

```
graph LR;
    A["SUPPLY  
12V 24V 220V"] --> B["JOINT  
IP-RATED / SEALED"];
    B --> C["CONTROL  
DALI Bluetooth DC0-10V ON/OFF DMX512"];
    C --> D["ELA719  
48W"];
```

MATCH SUPPLY, POLARITY, WIRE COUNT AND CONTROL TO THE COMPLETE PRODUCT CODE / LABEL.

1. Isolate the supply before excavation, connection, insertion or service.
2. Confirm the exact fixture and matching mounting part before preparing the recess.
3. Set the sleeve or channel level and flush; provide a permanent free-draining base.
4. Keep every cable entry and field joint sealed with the specified IP-rated system.
5. Commission only after the mechanical seat, seal and drainage are complete.

DO NOT SUBSTITUTE THE BURIAL PART, LEAVE A CABLE JOINT IN STANDING WATER OR INSTALL BELOW GRADE.

ELA719 VERIFIED SOURCE DATA

FIXTURE	D250 x H188.5 mm
MOUNTING	D228 x H219 mm SLEEVE
RECESS	MATCH SLEEVE / FREE-DRAINING
INPUT / POWER	12V 24V 220V / 48W
CCT	2700K/3000K/4000K/RGB/RGBW
CRI / BEAM	Ra 80 / 15° 25° 40° 60°
CONTROL	DALI Bluetooth DC0-10V ON/OFF DMX512
MATERIAL	304Stainless steel+6063#aluminum

Installation and commissioning must be performed by qualified technical personnel.

The D250 x H188.5 mm fixture shown above follows the ELA719 source sheet.

Use the exact product-specific mounting part: D228 x H219 mm BURIAL SLEEVE.

Coordinate recess, drainage, conduit, waterproof joints and finished grade before installation.

WARNING

- INSTALL THE FINISHED FACE FLUSH AND LEVEL; DO NOT LEAVE A TRIP EDGE.
- PROVIDE DRAINAGE; DO NOT PLACE THE CONNECTOR OR DRIVER IN STANDING WATER.
- ISOLATE POWER AND FOLLOW THE COMPLETE PRODUCT CODE / LABEL BEFORE CONNECTION.

CE IP FLUSH D DRAIN